

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 903

Dated: 2/2/26

It is certified that an inspection team headed by Shri. C.A. Kalele Chief Chemist
(Name of Officers with designation) from State Research Laboratory, PHED Bhopal,
inspected the Holy family convent S.R. Sec. School, Sanki Nagar Bhopal
(Name & Address of the school) on 1/2/26 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 903 dated 2/2/26
of State Research Laboratory, Bhopal (PHED Lab) certified that
the Holy family convent School S.R. Sec. Bhopal (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 1/8/26

Signature with Seal: 
Name: **CHUDAMANI KALELE**
Designation: **Chief Chemist**
Name & Address of the Office / Department: **State Research Laboratory
P.H. Eng. Dept. Bhopal**

To Holy family convent
S.R. Sec. School, Sanki Nagar Bhopal
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Test Report

Nature of sample :- Drinking Water Sample / Others		Not sampled by State Research Lab		Unique Identification No.	650-A
Sender's name and address To, HOLY FAMILY CONVENT SR.SEC.SCHOOL, SHANTI NAGAR BHOPAL		Sender's letter no.	-	Sender's letter Date	29/01/26
		SRL Ref. No	849	SRL receipt date	29/01/26
		Date of analysis started	29/01/26	Date of analysis completed	02/02/26
		Quantity Of sample	Ok		

Sample details

No.	Particulars of Samples
1.	R.O WATER SAMPLE

RESULTS

Field.. Testing No.	Characteristics/ Unit	Discipline..Chemical test methods	Group..Water		Sub. Group..Drinking Water				
			BIS -10500:2012 Reaffirmed In Sep 2022		Results				
			Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5					
1	Temperature in degree C	-	-	-	25°C	-	-	-	-
2	Iron as Fe mg/l	APHA 24 th edition, 3500-Fe B	1.0	No Relaxation	0.12	-	-	-	-
3	Manganese as Mg/l	Mn APHA 24 th edition 3500-mn-B	0.1	0.3	BDL	-	-	-	-
4	Odour	-	Objectionable	Unobjectionable	-	-	-	-	-
5	Phenolphthalein Alkalinity as CaCO ₃ mg/l	APHA 24 th edition, 2320 B	-	-	-	-	-	-	-
6	Sodium as Na mg/l	APHA 24 th edition, 3500 -Na B	-	-	-	-	-	-	-
7	Potassium as K mg/l	APHA 24 th edition, 3500 -K B	-	-	-	-	-	-	-
8	Dissolved Oxygen mg/l	-	-	-	-	-	-	-	-
9	Chemical Oxygen Demand (COD)mg/l	-	-	-	-	-	-	-	-
10	Biological Oxygen Demand (BOD) mg/l	-	-	-	-	-	-	-	-
11	Jar Test for Alum & lime dosing fixation mg/l	-	-	-	-	-	-	-	-
12	Purity of Alum	-	-	-	-	-	-	-	-
13	Purity of Lime	-	-	-	-	-	-	-	-
14	Purity of Bleaching	-	-	-	-	-	-	-	-
15	Chlorine test Demand	-	-	-	-	-	-	-	-
16	Ecoli	APHA 24 th edition, 9223 B	NIL	NIL	NIL	-	-	-	-
17	Total coliform per 100 ml	APHA 24 th edition, 9223 B	NIL for treated water and water in distribution system	NIL	-	-	-	-	-

- This report should not be produced partly or full without approval of signatory authority for legal purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the source will have to be rejected.
- The results refer only to tested samples and parameters tested
- Samples will be stored for a period of 15 days from the date of issue of report.
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- This report show only Non NABL parameters.

Retrieved by

for (Chudamani kalele)

Chief Chemist
STATE RESEARCH LABORATORY
P. H. E. DEPARTMENT BHOPALIssue No. 303 /S.R.L./PHED/BPL /2026 Issue Date 2/2/26